



ASME Accepted Manuscript Repository

Institutional Repository Cover Sheet

Mario Luigi

Ferrari

First

Last

Laboratory Tests in Cyber-Physical Mode for an Energy Management System Including
ASME Paper Title: Renewable Sources and Industrial Symbiosis

Authors: Mario L. Ferrari, Lorenzo Gini, Matteo Pascenti

ASME Journal Title: Journal of Engineering for Gas Turbines and Power

Volume/Issue 147 Date of Publication (VOR* Online) Jan. 2025

ASME Digital Collection URL: [Laboratory Tests in Cyber-Physical Mode for an Energy Management System Including
Sources and Industrial Symbiosis | J. Eng. Gas Turbines Power | ASME Digital Collection](#)

DOI: <https://doi.org/10.1115/1.4066249>

*VOR (version of record)



Laboratory Tests in Cyber-Physical Mode for an Energy Management System Including Renewable Sources and Industrial Symbiosis

Mario L. Ferrari

University of Genoa,
Genova 16126, Italy

Lorenzo Gini

University of Genoa,
Genova 16126, Italy

Matteo Pascenti

SIT Technologies s.r.l.,
Genova 16126, Italy

The aim of this paper regards the laboratory validation of an energy management system (EMS) for an industrial site on the Eigerøy island (Norway). It will be the demonstration district in the ROBINSON project for a consequent concept replication. This activity in cyber-physical mode is an innovative approach to finalize the EMS tool with real measurement data with prime movers available at laboratory level, considering the necessary EMS robustness and flexibility for replication on other industrial islands. This EMS was designed and developed to minimize variable costs, producing on/off and set-point signals that, through a model predictive control (MPC) software, establish the system status. This smart grid includes renewable sources (e.g., solar panels, a wind turbine, and syngas) and traditional prime movers, such as a steam boiler for the industry needs. Moreover, an energy storage device is installed composed of an electrolyzer with a hydrogen pressure vessel. The main results reported in this work regard 26-h tests performed in cyber-physical mode thanks to the real-time interaction of hardware and software. So, a real microturbine and real photovoltaic (PV) panels were managed by the EMS in conjunction with software models for components not physically present in the laboratory. Although the optimization target was cost minimization, significant improvement was also obtained in terms of efficiency increase and CO₂ emission decrease. [DOI: 10.1115/1.4066249]

Keywords: renewable energy, intelligent control, plant integration, energy storage

1 Introduction

The advanced integration of different energy systems and their optimization requires real-time software, which is usually called energy management system (EMS) [1]. Due to the ongoing and future energy transition aspects [2], this is also very important technology for integration with energy storage devices [3,4]. Although the smart grid optimization is performed in several literature studies [5,6], including different types of tools (e.g., genetic algorithms [7]) or different approaches (e.g., multilevel or multi-objective optimizations [8]), in a real field an EMS needs to be fast (real-time performance), flexible, and robust [9]. Moreover, since experimental validation is necessary before EMS application in real fields, the aim of this work is the innovative application of laboratory tests based on a cyber-physical approach. These needs are essential for industrialized districts on islands, such as for the scenarios analyzed in the European Union H2020 ROBINSON project [10]. In detail, attention is focused on the smart grid for an

industrialized district on the Eigerøy island (Norway), where the energy demands from the Prima Protein company (Egersund, Norway) (electricity and heat in the form of steam for obtaining fish products) are coupled with electricity needs of residential buildings and hydrogen demand for truck charging operations [10].

Starting from the development and validation of component models and the implementation of an EMS able to operate in real-time mode to manage energy storage systems (compressed hydrogen), attention is focused here on the EMS validation. Considering the simulation results presented and discussed in a previous study [9], which show the benefits due to the innovative integration with model predictive control (MPC) technology, experimental tests in cyber-physical mode were established. The activity was performed in the Innovative Energy Systems laboratory at the University of Genoa. Since it is not possible to have all the components at laboratory level and an experimental validation is necessary before proposing the EMS for the demonstration site (on the Eigerøy island), a cyber-physical approach was considered. This experimental solution was based on the coupling of real components in the laboratory with real-time models. This is an effective approach, as demonstrated in previous studies [11–13], to have a validated EMS in a flexible environment (a laboratory). So, this approach reduced

Turbo Expo, June 24–28, 2024. GT2024.

Manuscript received July 31, 2024; final manuscript received August 1, 2024; published online September 19, 2024. Editor: Jerzy T. Sawicki.

the risks and the development time in comparison with a direct application of the EMS after the simulations.

The main innovation of this paper regards the application of a cyber-physical approach for polygenerative grids, as an important validation bench for the proposed EMS. It is an important and innovative step to increase the EMS robustness, removing bugs and instability problems before operations at the real sites. Moreover, the positive results obtained in this study could propose this method for further smart grid systems, as planned in the ROBINSON project for concept replication [10]. In detail, the concept replication for industrial districts was already analyzed at both simulation and experimental levels in sites located in the Western Islands (UK) and in Crete (GR). While the simulation results for these replication activities are available in Ref. [14], the tests in cyber-physical mode for the Western Islands and Crete will be available soon on the project web site [10]. In detail, thanks to simulations reported in Ref. [14], the EMS application showed significant cost decrease: -33.3% for the Western Islands and -9.4% for Crete. The results demonstrated the potential benefits and the long-term impact related to large-scale application of the concept proposed and developed in the ROBINSON project. Moreover, due to layout and component size changes, this innovative cyber-physical approach, proposed here for the Eigerøy case, is also important for the EMS validation in replication cases. So, this proposed method will be an essential intermediate step for an easy EMS validation before performing operations at real sites (for further long-term application of the ROBINSON approach and results).

2 Plant and Energy Management System Layouts

This section regards the presentation of the smart grid plant layout, the component size on the basis of previous choices performed on the Eigerøy island, and the EMS layout and details.

2.1 Smart Grid Layout. The smart grid layout is shown in Fig. 1. It includes (1) a 400 kW (electrical power) gas turbine (the A400 machine [15]) fed by a fuel mixture (about 70% syngas, and 30% hydrogen in percentage terms), (2) a 22 MW (thermal power) boiler for steam production fed by liquefied natural gas, (3) two 500 kW electrolyzers (the power refers to electrical consumption), (4) a wood gasifier based on local resources to produce the 70% (in volume) of the turbine fuel, (5) a 100 kW size wind generator, and (6) 5.8 kWp photovoltaic (PV) panels.

The grid is also equipped with a hydrogen pressure vessel (40 m^3) for energy storage, and a gas mixer to produce the fuel for the microturbine. As shown in Fig. 1, the turbine (named combined heat and power system (CHP) for the generation of both electricity and thermal power) preheats the water (high temperature liquid water) upstream of the steam generation, as a thermal input for the boiler. The gasifier is not shown in Fig. 1 because it is operated by internal control systems to maintain the related internal buffer pressurization. So, it is not controlled by the EMS because it has very slow response performance (it cannot follow the load changes of the grid components). Although the ROBINSON project also includes an anaerobic digester–bioelectrochemical system to mix biogas in the turbine fuel, this system and the biogas line are not included in Fig. 1 because they are negligible from the EMS point of view (Eigerøy island case).

The component sizes were not calculated using an optimization process because the activity reported in this paper started from already installed components or decisions based on specific site needs. So, the boiler (already installed at the Eigerøy district) was chosen to satisfy the Prima Protein needs (thermal power for steam generation), the CHP turbine and the wind power generator were sized to provide electricity for an average site demand. Moreover, the electrolyzers were sized considering commercial devices available and to have a 6-h safety margin to operate the A400 at its maximum load. Finally, the hydrogen pressure vessel was defined on the basis of the available space and to ensure 12 h of continuous

autonomous operation for the A400 machine considering the hydrogen need of 30% (in volume) [9].

2.2 Energy Management System Layout. As already described in Ref. [9], the EMS is not a tool for scenario optimization with the availability of all the input data, but it needs to be a tool able to operate in real-time mode. This means that the demand values are the actual inputs from the field, not known in advance, but second by second (the general software time-step). Considering this aspect, the EMS was designed coupling an optimization with the scheduling of the hydrogen storage system. This approach for the hydrogen vessel is necessary because the demands are not known before the operations (as in several previous works). However, considering electricity costs forecasted on the basis of the previous day, it is possible to implement the management of this component. The entire tool (the EMS plus the models of components not available in the laboratory) runs in MATLAB-SIMULINK with a 1 s general time-step. Since the tool simulates one real second in a time shorter than 1 s using a standard personal computer, real-time performance is obtained activating the “pacing” function in the SIMULINK window.

The EMS is composed of two blocks, as shown in Fig. 1: a decision maker (including the market function) and an MPC software. The decision maker performs the minimization of the cost function (Eq. (1)), with a 15 min time-step, to calculate the values of preliminary set points (r in Fig. 1). The time-step change (from the general to the optimizer) is obtained using the SIMULINK rate transition components. As reported in Ref. [9], the optimization is based on a constrained, nonlinear algorithm (the “patternsearch” function from MATLAB) that minimizes the variable costs, including fuel (Eq. (2)), electricity and operation and maintenance (O&M) costs. The decision variables are the electrical power set-point values for the CHP and the amount exchanged with the grid (including the possibility of decreasing the selling cost in comparison with the buying costs, as in Eq. (3)). The constraints are the electrical balance equation (the missing electrical power or its excess is the power exchanged with the grid) and the minimum/maximum ranges reported in Table 1.

Moreover, three cases were implemented from the thermal generation point of view (Fig. 2): (a) thermal demand lower than the CHP minimum, (b) intermediate condition, (c) thermal demand higher than the CHP maximum thermal generation. For all three cases, two options are included: if the electrical generation is profitable, the turbine is managed at its optimal condition (usually at its maximum), in the opposite case the CHP is operated at its minimum load (for case a), to supply the thermal power needs (case b) or switched off (case c) [9]

$$J_{\text{cost}} = (c_{\text{el}} + c_{\text{O\&M}}) \cdot P_{\text{el,grid}} + c_{\text{fuel,CHP}} \cdot m_{\text{fuel,CHP}} + c_{\text{st}} \cdot N_{\text{st}} \quad (1)$$

$$m_{\text{fuel,CHP}} = f(P_{\text{el,CHP}}, \text{LHV}_{\text{CHP}}, \eta_{\text{CHP}}, T_{\text{amb}}) \quad (2)$$

$$c_{\text{el}} = \begin{cases} c_{\text{el}} & \text{if } P_{\text{el,grid}} > 0 \\ c_{\text{el}} * \text{Sell} & \text{if } P_{\text{el,grid}} < 0 \end{cases} \quad (3)$$

The second tool is a controller that includes predictive technology for the calculation of the actual component set-points. Since the components have their own control systems, the EMS produces only the on/off signals and the set-point values. The control operations on the internal components (e.g., actuation of the fuel valves) are performed by the specific commercial controllers of each device. This is an important approach, already considered in previous studies, taking into account the different dynamic response performance of the devices (e.g., the difference between the CHP fast electrical responses with the long time necessary for the boiler dynamics). This is an MPC tool that was developed on the basis of the procedure by Wang [16]. An initialization defines the time window for the prediction horizon ($N_p = 40$ steps) and the control horizon ($N_c = 1$ step). This MPC was developed with information related to the components (the CHP and the steam boiler), using a




Fig. 1 Plant layout and EMS integration

Table 1 Constraints of the optimization tool

Parameter	Min value	Max value	Unit
CHP EL power	70	400	kW
Grid EL power	−2000	2000	kW
Boiler TH power	2200	22,000	kW

linearized state-space representation. So, the architecture of this MPC includes the following functions: one regards the discrete model predictive control (DMPC) and the second one regards the observer [16]. The model (for control implementation) uses an augmented state-space approach, i.e., nonminimal state space [16]. The observer estimates the state of the system that is provided to the DMPC dynamic software. The MPC integration is performed with the Laguerre network (to simplify computations with tunable parameters). One of the MPC advantages regards the possibility of response tuning operating on weights associated with control variables. In this work, cost function is based on discrete linear quadratic regulator architectures, as in Eq. (4). The tool includes the following elements: Q and R are weight matrices, x is the state of the system, and a is the control signal. The DMPC algorithm includes constraints on plant inputs (a) and their rate of change Δa

$$J = \frac{1}{2} x^T Q x + a^T R a \quad (4)$$

In agreement with the issues mentioned to manage a storage device in a real-time environment, the electrolyzers are operated at maximum load when the electricity has a price lower than the average value (FLAG = 1 in Fig. 3). On the other hand (FLAG = 2 in Fig. 3), they are operated by a devoted controller in the opposite case, with a pressure set-point at its minimum value. In this case, the target pressures for the hydrogen vessel were: 40 bar (in case of low electricity price) or 22 bar (in case of high electricity price). These values were defined to obtain a good compromise between the necessity to avoid overpressure conditions and to provide a good margin for energy safety. They are not definitive for the real application, but represent reasonable values.

3 Test Rig and Experimental Approach

To validate the EMS with real interactions with hardware components, as planned in the ROBINSON project [10], attention was focused on laboratory activities. This is an important step to check the EMS behavior in terms of stability and performance with data coming from a real environment.

3.1 Test Rig. The experimental plant is a test bench installed in previous activities in the Innovative Energy Systems laboratory at the University of Genoa [17]. This is a local grid, including the following generation devices: a T100 gas turbine in CHP mode, a 20 kW heat pump, thermal solar panels (10 kWp), photovoltaic panels (1.1 kWp), an absorption chiller, two thermal energy storage tanks for hot water (5 m³ for each device), a thermal grid based on two distribution ducts and equipped with fan coolers (local thermal load generation), and an electrical grid connection. Since in this work attention regarded the Eigerøy site, the tests were carried out using only the following laboratory components: (a) the T100 turbine, (b) the PV panels, (c) the connection to the electrical grid, and (d) the thermal grid.

3.2 Tests in Cyber-Physical Mode. Due to the fact that the laboratory is not equipped with all the components of the Eigerøy site, the tests reported in this work were carried out in cyber-physical mode. This means that software and hardware operated connected, communicating in real-time mode. This allows one to introduce experimental aspects (e.g., typical measurement oscillations), avoiding additional costs and risks related to the planned application at the real site. This cyber-physical mode was important to produce experimental results for the EMS validation and possible improvements (if necessary). The software/hardware interaction is reported in Fig. 4. The software input data are four measurements: electrical power from the T100 generation (affected by $\pm 1\%$ accuracy), thermal power from the turbine generation (affected by $\pm 3\%$ accuracy), fuel mass flow consumed by the turbine (affected by $\pm 1\%$ accuracy), and power value generated by the PV panels (affected by $\pm 1\%$ accuracy). To complete the cyber-physical approach, the hardware input data are two values calculated by the




Fig. 2 Flowchart of the EMS logic

software in real-time mode: turbine on–off (activation) signal and its set-point values (electrical power). Due to the different sizes of the components, a data conversion system was implemented to use the T100 turbine for tests related to a 400 kW turbine. In detail, the size ratio between the two machines was used in the conversion gains for the electrical values. Moreover, the measured thermal power from the T100 was multiplied by the ratio between the design thermal powers of both devices. The PV panels also included a rescaling due to a different amount of PV area available in the laboratory, in comparison with what is installed at the Eigerøy site. So, the measured power was multiplied by a scaling factor (the ratio between the panel areas in the Eigerøy and the laboratory sites).




Fig. 3 Electricity costs considered in this article and flags for the management of the electrolyzers

In conclusion, the cyber-physical approach proposed and used in this study does not include complex tools, but a direct real-time communication between the EMS (and the rest of the software) and the laboratory hardware. Depending on the smart grid layout and the available devices at laboratory level, the connection with other hardware is simple. Due to the necessity to have real-time interaction, the hardware/software communication is obtained with user datagram protocol channels based on the available components in SIMULINK and in the laboratory data acquisition software (LabVIEW).

3.3 Component Models. For the tests performed in this study, detailed tools were not necessary because the EMS needed just the global performance values (e.g., electrical and thermal power). So, the boiler, the wind turbine, and the electrolyzers were modeled with black-box solutions including design, off-design and dynamic calculations. In detail, the time-dependent behavior was calculated including dead-time and first-order delay tools on the basis of manufacturers' data or literature information. This is a good compromise between fast calculation performance and reasonable accuracy.

The wind turbine model was based on the performance curve from the manufacturer. The model received the wind speed in real-time mode and calculated the electrical power generated.

For the electrolyzers [18], the simulation was performed with two models including part-load performance curves and dynamic behavior from literature data [14]. In detail, the dynamic response of these components was calculated with first-order delay, as confirmed by the manufacturer.

Specific attention was necessary for the hydrogen storage vessel and the fuel mixer. To use a physical-based dynamic approach (mainly continuity and energy equations in dynamic conditions—Eqs. (5) and (6)), the TRANSEO tool models were used [19].

Software (including the EMS) Hardware (CHP+PV)




Fig. 4 Hardware/software communication for the cyber-physical approach

Moreover, the adiabatic plenum concept was integrated with the 0D approach for heat exchanges, as previously developed and validated in TRANSEO for the component named “pipe” [19]. These tools also calculate the outlet composition (and the related properties), using mass balances for each mixture component and a thermodynamic library of functions for the other properties, such as the specific heat of the mixture. For instance, in Ref. [20] the pressurization time was correctly calculated using the TRANSEO pressure vessel (the results were in good agreement with the data measured). Moreover, in Ref. [20] the composition management (the same approach used here) showed results matching the experimental data well

$$\frac{dM}{dt} = \sum m_{in} - \sum m_{out} \quad (5)$$

$$\frac{d(M \cdot T_{out})}{dt} = \frac{c_{p,out}}{c_v} \left[\sum (m_{in} \cdot T_{in}) - \sum (m_{out} \cdot T_{out}) \right] \quad (6)$$

Finally, it is important to mention that the real-time models used in this work (for components not available in the laboratory) were fully validated in a previous study [9] against experimental data or considering literature information (e.g., in Ref. [21]).

The boiler model was validated against experimental data provided by Prima Protein (Fig. 5) with $\pm 3\%$ accuracy, considering




Fig. 5 Boiler model validation

a set-point step from 3 MW to 16.5 MW. The model was able to reproduce the general dynamic trend of the proposed data with good agreement. Since no experimental data are available for the hydrogen pressure vessel or for the mixer, the related models are considered validated on the basis of the results obtained in previous studies (e.g., in Ref. [19] where good agreement was obtained between a dynamic model including pressure vessels and experimental measurements).

4 Results and Discussion

In spite of the long duration of the experimental tests (26 h plus the startup/shutdown phases), two different 26-h tests were performed in the laboratory. It is important to highlight that the results reported here were obtained after preliminary tests that highlighted the necessity to stabilize the tool better. So, this showed the importance of tests because, although the EMS was stable in just simulation mode [9], oscillations coming from measurements required improvements to have stable behavior.

Due to a completely different behavior depending on the syngas cost values, these results were performed considering two cases for the cost of syngas produced by the gasifier: €80/MWh and €5/MWh. Since no real data are available at this development stage of the activity, two different opposite values were considered. While the €5/MWh case is close to realistic values, the opposite situation was considered with high cost condition. The high cost case (€80/MWh) generated special interest in the laboratory test because this condition produced load changes in the CHP, while a low syngas cost moved the optimizer to maintain the CHP at maximum, exploiting the benefits in selling electrical energy. As performed in Ref. [9], in both syngas cost conditions, the results obtained with the EMS were compared with the related “no EMS” case. This reference was obtained with simulations considering a simple approach that did not require any intelligence or optimization. So, in the no EMS curves: the CHP was operated to satisfy the missing electrical demand (electricity demand minus the production by the renewable source that was significantly present mainly due to wind turbine operations in the late afternoon hours), the boiler was controlled through a proportional–integral (PI) tool to produce the missing thermal power (Fig. 6), and the electrolyzers were maintained at the minimum load for the entire test. It is important to highlight that, instead of using the thermal demand directly as boiler set-point, the PI in Fig. 6 was included to properly consider the slow boiler response performance. Since there are no specific results or




Fig. 6 PI tool for the boiler set-point calculation in the no EMS cases

simulations for a reference case (or cases), this approach was chosen to have something simple and reasonable considering the necessity to satisfy the demands.

Finally, it is important to highlight that for all cases reported in the paper the selling/buying ratio was equal to 1 because, due to the preliminary condition of the Eigerøy site, no data are available for this aspect at the current development stage. Moreover, the following syngas composition was used: 3% CH₄, 44% N₂, 12% CO₂, 20% CO, and 21% H₂. These values were chosen on the basis of typical syngas flows produced from wood gasification, because site data on this are not available at the current development stage.

4.1 €80/MWh Syngas Cost. The €80/MWh case for the syngas cost was chosen because, in the 26 h, this produced different conditions: situations when it was profitable to reduce or switch off the CHP due to low electricity price to sell and conditions that moved the EMS to operate the CHP at maximum load (to produce earnings from electricity selling to the grid). In detail, this aspect is clear in Fig. 7 for electrical power management. While in the no EMS case, the CHP followed the demand trend and the missing power was provided by the grid, the EMS decided to maintain the CHP at low load when electricity selling was not profitable and increased the load at high electricity costs. Moreover, when the electricity selling was not profitable and the boiler was active (close to the hour number 14 in Fig. 7) the CHP was switched off (a minimum negative power regarded the ventilation or the startup consumptions of the CHP).

From the thermal generation point of view, Fig. 8 shows that the boiler was activated when the thermal demand started to be significant and higher than the maximum thermal generation by the CHP. While the predictive performance of the MPC was able to properly manage the boiler to cover the thermal demand, the PI tool produced significant oscillations with missing or excessive power situations. Due to the PI-based approach in the no EMS case and the slow boiler response, following the boiler activation there are zones with excessive thermal generation because the PI tried to increase the set-point to compensate the error. Although this additional generation is nullified in long-term operations, the error in load




Fig. 7 Electrical power comparison (EMS versus no EMS cases) for the €80/MWh syngas cost




Fig. 8 Thermal power comparison (EMS versus no EMS cases) for the €80/MWh syngas cost

change following highlighted the importance of the MPC tool. The gap between the demand and the boiler generation was the thermal power produced by the CHP. So, a demand-boiler matching was present when the CHP was switched off.

For the hydrogen management side, Fig. 9 shows the vessel pressure, the electrolyzer power and the inlet/outlet flows. While a base hydrogen consumption was present due to the CHP need, two truck charging phases of 13.3 g/s are visible (2400 s duration in both cases). The initial charging operation was at 3:00 a.m. while the second one was at 9:15 a.m. Since no data are available for such hydrogen consumption because this will be related to future operations at the Eigerøy site, this could be representative of a typical consumption for large vehicles. Different operations could also be implemented in future studies considering statistic data.

The results reported in Fig. 9 show that the EMS was able to manage the electrolyzers performing proper charging operations during the FLAG = 1 situations. So, the EMS was able to recharge the hydrogen vessel obtaining a final pressure close to the initial one. On the other hand, a non managed approach (e.g., the no EMS case) produced a final hydrogen tank pressure significantly lower than the initial one. Since this is linked with missing stored energy at the end of the period, this is taken into account in the result comparison section for the calculation of the global system performance.

4.2 €5/MWh Syngas Cost. This second case, although more realistic from a cost point of view, was less significant for laboratory




Fig. 9 Comparison (EMS versus no EMS cases) for the hydrogen generation, storage, and utilization (€80/MWh syngas cost)




Fig. 10 Electrical power comparison (EMS versus no EMS cases) for the €5/MWh syngas cost




Fig. 11 Thermal power comparison (EMS versus no EMS cases) for the €5/MWh syngas cost

operations because for the EMS it was always profitable to operate the CHP at maximum load to sell the possible electricity excess to the grid. So, while Fig. 10 shows the same behavior as Fig. 7 for the no EMS case, the application of the EMS tool produced a CHP behavior at 400 kW (electrical power) for the entire 26-h test.

On the thermal side (Fig. 11), this test with €5/MWh syngas cost produced a constant thermal generation at the CHP maximum. As in the previous case, the EMS was able to manage the boiler to properly cover the thermal power demand.

From the hydrogen management point of view, Fig. 12 shows similar aspects to that presented and discussed for Fig. 9. However, a constant outlet hydrogen flow is visible (except for the truck charging phases) due to the constant 400 kW set-point on the electrical side.

4.3 Comparison of Global Parameters. To finalize the EMS validation in cyber-physical mode, a comparison of global parameters was performed for all 26 h. The variable costs significantly decreased in comparison with the no EMS cases (Fig. 13) due to the fact that the cost minimization is the objective chosen here. In Fig. 13, it is important to include the two different costs of the no EMS cases due to different syngas costs. The bars for the €5/MWh case show, obviously, a lower global cost in comparison with the results obtained with €80/MWh in respective conditions. The cost decrease performance was significant due to the utilization of




Fig. 12 Comparison (EMS versus no EMS cases) for the hydrogen generation, storage, and utilization (€5/MWh syngas cost)




Fig. 13 Comparison of global variable costs for the cases discussed in this paper (full 26-h duration)

the EMS tool: −6.8% for the test with €80/MWh syngas cost and −8.3% for the €5/MWh case

$$\eta_{\text{elCHP}} = \frac{E_{\text{elCHP}}}{E_{\text{fuelCHP}}} \quad (7)$$

$$\eta_{\text{el system}} = \frac{E_{\text{elCHP}} + E_{\text{H2users}} + \Delta E_{\text{H2storage}}}{E_{\text{fuelCHP}} + E_{\text{el grid}}} \quad (8)$$

A second parameter discussed here and reported in Fig. 14 is the electrical efficiency for the CHP alone and the integrated system (as defined in Eqs. (7) and (8), respectively). The terms in Eqs. (7) and (8) refer to total energy (produced, consumed, or stored) for all 26 h. In detail, the term E_{H2users} is the energy (produced hydrogen mass for truck charging in the 26 h per hydrogen LHV) and the term $\Delta E_{\text{H2storage}}$ is the energy difference in the hydrogen tank between the −2 h and the 24 h (it is positive in case of more hydrogen available at




Fig. 14 Comparison of system electrical efficiency for the cases discussed in this paper (full 26-h duration)




Fig. 15 Comparison of CO₂ emissions for the cases discussed in this paper (full 26-h duration)

the end of the test in comparison with the beginning, and it is negative in the opposite case). For the CHP electrical efficiency, no benefits were obtained because it decreased (−7.6%) for the syngas cost value of €80/MWh (due to the fuel consumption during the restart phase) and the increase obtained for €5/MWh syngas cost was not significant (+0.9%). However, the benefits obtained for the system electrical efficiency were more important and significant: +13.6% for the €80/MWh syngas cost and +29.7% for the other case.

Although not optimized by the EMS, it is also important to report the comparison of mass of CO₂ emitted for these 26-h tests. The values reported in Fig. 15 were calculated using Eq. (9), as already presented in Ref. [9]. For these 26-h tests, significant emission decrease was obtained with the EMS application: −8.3% for the syngas cost equal to €80/MWh case and −8.9% for the second test

$$M_{CO_2, \text{system}} = M_{CO_2, \text{boiler}} + M_{CO_2, \text{electrolyzers}} + M_{CO_2, \text{grid}} + \Delta M_{CO_2, H_2 \text{ storage}} \quad (9)$$

5 Conclusion

The experimental results (in cyber-physical mode) obtained in this study validated the proposed EMS for polygeneration grid operations. Following the simulation results in Ref. [9], this experimental campaign was essential to confirm the software robustness and its performance considering Eigerøy island (the demo site for the ROBINSON project). So, this innovative approach for these kinds of smart grid applications was considered for two 26-h tests producing the following performance results:

- Significant cost decrease (the objective of this optimization tool) for both syngas cost scenarios (−6.8% for €80/MWh and −8.3% for the €5/MWh case).
- The EMS also produced important system efficiency increase for the electrical side (as in Eq. (8)): +13.6% for the €80/MWh syngas cost and +29.7% for the other case.
- The efficiency increase also generated a positive impact on CO₂ emissions: −8.3% for the syngas cost equal to €80/MWh case and −8.9% for the second test.

Considering the positive results of this study, this EMS is ready for application in the real demo site and for its replication in the following sites proposed by the ROBINSON project [10]. Moreover, further applications will be considered for a long-term development of the proposed concept, including the innovative cyber-physical approach.

Acknowledgment

This project has received funding from the European Union's Horizon 2020 research and innovation programme under Grant Agreement No. 957752. This paper reflects only the authors' views and the Research Executive Agency and the European Commission are not responsible for any use that may be made of the information it contains.

Funding Data

- European Union's Horizon 2020 research and innovation program (Grant Agreement No. 957752; Funder ID: 10.13039/501100000780).

Data Availability Statement

The datasets generated and supporting the findings of this article are obtainable from the corresponding author upon reasonable request.

Nomenclature

CHP = combined heat and power system
 DMPC = discrete model predictive control
 EL = electrical
 EMS = energy management system
 MPC = model predictive control
 O&M = operation and maintenance
 PI = proportional–integral controller
 PV = photovoltaic
 TH = thermal
 TRL = technology readiness level

Variables

a = plant inputs for the MPC
 c = cost (€)
 c_p, c_v = specific heats (J/(kg K))
 E = energy (J)
 J = cost function (€)
 k = number of the component
 LHV = low heating value (J/kg)
 m = mass flow rate (kg/s)
 M = mass (kg)
 N_C = control horizon
 N_P = prediction horizon
 N_{st} = startup number
 p = pressure (Pa)
 P = power (W)
 Q, R = weight matrices for the MPC
 r = set-points by the decision maker (W)
 Sell = selling/buying ratio for electricity
 SP = set-point (W)
 t = time (s)
 T = temperature (K)
 u = set-points for the components (W)
 x = system state in the MPC
 y = measurements for the EMS (W)
 η = efficiency

Subscripts

amb = ambient
 CHP = combined heat and power
 el = electrical
 Electr = electrolyzer
 in = inlet
 out = outlet
 O&M = operation and maintenance
 th = thermal

References

- [1] Tan, B., Chen, S., Liang, Z., Zheng, X., Zhu, Y., and Chen, H., 2024, "An Iteration-Free Hierarchical Method for the Energy Management of Multiple-Microgrid Systems With Renewable Energy Sources and Electric Vehicles," *Appl. Energy*, **356**, p. 122380.
- [2] Bellotti, D., Rivarolo, M., and Magistri, L., 2022, "A Comparative Techno-Economic and Sensitivity Analysis of Power-to-X Processes From Different Energy Sources," *Energy Convers. Manage.*, **260**, p. 115565.
- [3] Barberis, S., Rivarolo, M., Bellotti, D., and Magistri, L., 2022, "Heat Pump Integration in a Real Poly-Generative Energy District: A Techno-Economic Analysis," *Energy Convers. Manage.*, **X**, **15**, p. 100238.
- [4] Vannoni, A., Garcia, J. A., Guedez, R., Sorce, A., and Massardo, A. F., 2023, "Combined Cycle, Heat Pump, and Thermal Storage Integration: Techno-Economic Sensitivity to Market and Climatic Conditions Based on a European and United States Assessment," *ASME J. Eng. Gas Turbines Power*, **145**(2), p. 021007.
- [5] Bozzo, M., Caratozzolo, F., and Traverso, A., 2012, "Smart Polygeneration Grid: Control and Optimization System," *ASME Paper No. GT2012-68568*.

- [6] Ferrari, M. L., Gini, L., Di Barba, P., Mognaschi, M. E., and Sieni, E., 2024, "Multi-Objective Optimization of a Polygeneration Grid Including Thermal Energy Storage System," *J. Energy Storage*, **97**, p. 112963.
- [7] Javaid, N., Javaid, S., Abdul, W., Ahmed, I., Almogren, A., Alamri, A., and Niaz, I. A., 2017, "A Hybrid Genetic Wind Driven Heuristic Optimization Algorithm for Demand Side Management in Smart Grid," *Energies*, **10**(3), pp. 319–327.
- [8] Ali, S., Ullah, K., Hafeez, G., Khan, I., Albogamy, F. R., and Haider, S. I., 2022, "Solving Day-Ahead Scheduling Problem With Multi-Objective Energy Optimization for Demand Side Management in Smart Grid," *Eng. Sci. Technol., Int. J.*, **36**, p. 101135.
- [9] Ferrari, M. L., Gini, L., and Maccarini, S., 2023, "Energy Management System for Smart Grids Including Renewable Sources and Industrial Symbiosis," *ASME Paper No. GT2023-102402*.
- [10] ETN Global, 2024, "Robinson," ETN Global, Saint Gilles, Belgium, accessed Apr. 1, 2024, <https://www.robinson-h2020.eu/>
- [11] Marcellan, A., Abrassi, A., and Tomberg, M., 2019, "Cyber-Physical System of a Solid Oxide Fuel Cell/Micro Gas Turbine Hybrid Power Plant," *E3S Web Conf.*, **113**, p. 02006.
- [12] Ferrari, M. L., Zaccaria, V., and Kyprianidis, K., 2021, "Pressurized SOFC System Fuelled by Biogas: Control Approaches and Degradation Impact," *ASME J. Eng. Gas Turbines Power*, **143**(6), p. 061006.
- [13] Tsai, A., Banta, L., Tucker, D., and Gemmen, R., 2010, "Multivariable Robust Control of a Simulated Hybrid Solid Oxide Fuel Cell Gas Turbine Plant," *ASME J. Fuel Cell Sci. Technol.*, **7**(4), p. 041008.
- [14] ETN Global, 2024, "Preliminary Performance of Integrated System Operating With the Management Tool," ETN Global, Saint Gilles, Belgium, accessed Apr. 1, 2024, <https://www.robinson-h2020.eu/wp-content/uploads/2023/09/D3.3-Preliminary-performance-of-integrated-system-operating-with-the-management-tool.pdf>
- [15] Jaatinen-Värri, A., Nerg, J., Uusitalo, A., Ghalamchi, B., Uzhegov, N., Smirnov, A., and Malkamäki, M., 2016, "Design of a 400 kW Gas Turbine Prototype," *ASME Paper No. GT2016-56444*.
- [16] Wang, L., 2009, *Model Predictive Control System Design and Implementation Using MATLAB®*, Springer, London, UK.
- [17] Ferrari, M. L., Traverso, A., Pascenti, M., and Massardo, A. F., 2014, "Plant Management Tools Tested With a Small-Scale Distributed Generation Laboratory," *Energy Convers. Manage.*, **78**, pp. 105–113.
- [18] Maamouri, R., Guilbert, D., Zasadzinski, M., and Rafaralahy, H., 2021, "Proton Exchange Membrane Water Electrolysis: Modeling for Hydrogen Flow Rate Control," *Int. J. Hydrogen Energy*, **46**(11), pp. 7676–7700.
- [19] Ferrari, M. L., Traverso, A., Pascenti, M., and Massardo, A. F., 2007, "Early Start-Up of Solid Oxide Fuel Cells Hybrid Systems With Ejector Cathodic Recirculation: Experimental Results and Model Verification," *Proc. IMechE, Part A, Power Energy*, **221**(5), pp. 627–635.
- [20] Ghigliazza, F., Traverso, A., Massardo, A. F., Wingate, J., and Ferrari, M. L., 2009, "Generic Real-Time Modeling of Solid Oxide Fuel Cell Hybrid Systems," *ASME J. Fuel Cell Sci. Technol.*, **6**(2), p. 021312.
- [21] Mantelli, L., Ferrari, M. L., and Traverso, A., 2021, "Dynamics and Control of a Turbocharged Solid Oxide Fuel Cell System," *Appl. Therm. Eng.*, **191**, p. 116862.